

Sixth Northwest Conservation & Electric Power Plan

## Concentrating Solar Power (CSP) Resource Assessment

Jeff King

Northwest Power and Conservation Council  
Generating Resources Advisory Committee

Portland, OR

December 9, 2008



December 18, 2008

## CSP considerations and issues I

Potentially available in very large quantity

Little direct production of carbon dioxide or criteria air pollutants (SO<sub>x</sub>, NO<sub>x</sub>, etc.)

- Power tower and parabolic-trough technologies may employ gas backup for stabilization of output and for providing peaking capacity value

Potential ecological impacts from habitat preemption

- Large land area required

Public perception:

- Power plants - cautiously supportive (concerns regarding land use, aesthetics and ecological impacts)
- New transmission needed from remote resource areas - possible public resistance



December 18, 2008

## CSP considerations and issues II

### Investment risk:

- High capital cost (currently \$4000 - 5000/kW)
- Short development and construction lead time
- Advanced development of longer-lead time transmission will be needed to access suitable resource areas

### Low fuel price risk

### Diurnally intermittent and seasonally variable output

- Probably less forecast error than windpower
- Parabolic trough and power tower systems can include thermal storage and gas backup to stabilize output
- Reduces or eliminates regulation and load-following costs

### Northwest perspective:

- Poor seasonal load-resource coincidence for most of region
- New transmission in new corridors needed to access resource
- Price competition from California & SW utilities



December 18, 2008

## Power Tower

Field of heliostats (tracking mirrors) focus radiation on central tower-mounted receiver

Molten salt heat transfer fluid transfers energy to salt/water boiler; steam drives conventional steam turbine generator

Molten salt thermal storage and supplemental natural gas boiler firing may be provided.

~ 20 MW unit capacity

### North American Development

10 MW Solar One pilot project (1982 -1988), Barstow, CA

10 MW Solar Two pilot project (molten salt heat transfer fluid & thermal storage) (1998 - 1999), Barstow, CA.

Power sales agreements for 6 projects totalling 1145 MW in CA



December 18, 2008

## Dish/Engine

Heat-driven engine/generator (usually Stirling) at focal point of mirrored dish.

Highly modular (25kW/unit); opportunities for economies of production.

Scalable to arrays of several hundred megawatts, or more.

### North American Development

150 kW (6 dish) pilot plant in operation

Power sales contract w/SDGE for 300 MW (12,000 dish) plant in the Imperial Valley, CA

Power sales contract w/ SCE for 500 MW (20,000) dish plant in the Mojave Desert, CA



December 18, 2008

## Parabolic-trough

Mirrored parabolic troughs or linear Fresnel lenses focus radiation on a linear oil-filled receiver

Oil heat transfer fluid transfers energy in an oil/water boiler; steam drives conventional steam turbine generator

Oil thermal storage and supplemental natural gas boiler firing may be provided.

1 - 200 MW unit capacity

### North American Development:

SEGS I - X (354 MW total) in service in California since late 1980s

64 MW Nevada Solar One in service in 2007

5 MW Kimberlina Linear Fresnel Reflector plant in service 2008 (CA)

Power sales agreements for 4 projects totalling 1180 MW in CA & AZ

Power sales agreements for 177 MW Carrizo Plains Fresnel Reflector project



December 18, 2008

## Parabolic trough selected for further analysis

Each technology is likely ultimately to play a commercial role  
Parabolic-trough technology is commercially proven with an extensive operating record


### Cost:

- Dish Stirling cost estimates somewhat higher than Power Tower or Parabolic Trough, but are very preliminary and may benefit from economies of production
- Power Tower and Parabolic trough costs are roughly in the same range, but parabolic trough costs are firmer, based on commercial-scale construction and extended (20 years) of operation.



December 18, 2008


## CSP technologies use direct normal radiation Best sites are in the desert Southwest.




December 18, 2008

We assumed development in the White River Valley of Nevada

6.5 - 7.5 kWh/m/day  
 ~ 100 mi south of Thirtymile substation of proposed Southwest Intertie Project




Central NV CSP to S. Idaho, Oregon & Washington




December 18, 2008

## Derivation of CSP capital cost assumption



December 18, 2008

## Construction costs over the long-term



December 18, 2008

## CSP Plant assumptions

### Configuration:

- 200 MW parabolic trough power plant
- Natural gas backup (10,000 Btu/kWh HR) and 6 hours storage
- 40% capacity factor

### Development and construction cost (overnight):

- \$4700/kW (2010 service)
- \$4100/kW (2015 service)

### Operating costs:

- Fixed O&M - \$60.00/kW/yr
- Variable O&M - \$1.00/MWh
- System Integration - None (Storage & backup NG used for stabilization)

### Schedule and cash flow

- Development - 24 mo; 2% of overnight cost
- Preparation - 8 mo (4 mo overlap w/development); 20% of overnight cost
- Construction - 24 mo; 78% of overnight cost

### Earliest service for project available to the Northwest ~ 2015

- Prerequisite: Construction of transmission



December 18, 2008

## Transmission assumptions


- Incremental transmission system cost fully allocated to CSP energy transfer (no network reliability credit).
- Transfer capacity provided for 100% of project output.
- Transfer cost based on expected capacity factor (~40%)
- Estimates based on line miles and substations proposed for B2H, appropriate Gateway, SWIP North segments.
- Assumed additional 100 mi lateral + receiving substation w/transformation from White River Valley to SWIP Thirtymile sub.
- Lines assumed to be single-circuit 500kV AC w/1500 MW transfer capacity
- Line and substation unit costs are as recommended by Bonneville Nov 2008.
- ROW, communication, EPC, owner's cost and O&M cost percentages are from MSTI proposal.
- Losses are from 2006 NTAC Canada-Northwest-California study



December 18, 2008




## CSP plant cost elements



\* Fixed fuel cost would be about \$25/MWh if pipeline capacity to provide firm peaking capacity were secured.

December 18, 2008

## Effect of historical and forecast cost trends



December 18, 2008