

Bill Bradbury
Chair
Oregon

Henry Lorenzen
Oregon

W. Bill Booth
Idaho

James A. Yost
Idaho



Northwest Power and Conservation Council

Jennifer Anders
Vice Chair
Montana

Pat Smith
Montana

Tom Karier
Washington

Phil Rockefeller
Washington

September 3, 2014

MEMORANDUM

TO: Power Committee Members

FROM: John Fazio, Senior Systems Analyst

SUBJECT: Primer on Resource Adequacy

BACKGROUND:

Presenter: John Fazio, NWPCC (jfazio@nwcouncil.org, 503-222-5161)

Summary: In power system planning, there has always been a tradeoff between cost and adequacy (or reliability). A utility can invest more money in its resource supply to better insure that power will be available more often and under more extreme conditions. But how much is enough? The Regional Portfolio Model (RPM) explicitly calculates the average cost and risk (tail-end cost) for various future resource plans. However, the Council has agreed that some level of minimum adequacy must be provided. That minimum level of adequacy is defined in the Council's standard, which limits the likelihood of a future shortfall to 5 percent or less (when counting only existing resources and those expected to be operational). This briefing describes the metric used by the Council to assess the adequacy of the regional power supply and also describes other adequacy metrics used around the world.

Relevance: As the Council proceeds with the development of its 7th power plan, it must insure that its final resource strategy will result in an adequate supply. The Council's adequacy standard must be incorporated into all of its planning models.

Work Plan: B. Assess adequacy for 2019

Background: Resource adequacy is one part of the Council's mandate, which is to develop a resource plan that will provide an adequate, efficient, economic

and reliable power supply for the Pacific Northwest. John will present background information on the method adopted by the Council in 2011 to assess resource adequacy.

More Info: <http://www.nwcouncil.org/energy/resource/home/>


Primer on Resource Adequacy

Power Committee
September 9, 2014
Portland, Oregon



Outline

- Tradeoff between cost and adequacy
- The GENESYS model
- The Council's Adequacy Standard
- Calculating LOLP
- Other adequacy metrics



The GENESYS Northwest Model

A Monte-Carlo model that simulates the operation of the NW power supply system over many different uncertain future conditions

Uncertain Future Conditions:


- Water supply
- Temperature (load)
- Wind generation
- Forced outages

Specifics:

- Detailed hydro simulation
- Dynamic Hydro/Thermal dispatch
- Economic dispatch
- Hydro blocks priced relative to specific thermal units
- Hourly time step

Northwest Power and Conservation Council



nwcouncil.org




Resource Dispatch Order

Resource	Description	
Firm Hydro and Thermal	From lowest to highest operating cost	Modeled in GENESYS
Non-firm and Markets	In-region and out-of-region markets, surplus hydro, borrowed hydro	
Standby Resources Type 1	Non-declared utility resources (diesel generators, etc.)	Modeled in Post Processor
Standby Resources Type 2	Buy-back provisions on load	
Emergency Action 1	More expensive non-declared resources or contract provisions	Not Modeled
Emergency Action 2	Governor's call for conservation	
Emergency Action 3	Rolling black outs or brown outs	

nwccouncil.org








Council's Adequacy Standard (Adopted in Dec 2011)

- **Goal**
Measure the likelihood of having at least one curtailment in a future year
- **Method**
Number of games with at least 1 curtailment divided by the total number of games
- **Metric**
Loss of load probability (LOLP)
- **Threshold**
Maximum of 5%


Northwest Power and Conservation Council 10 nwcouncil.org



Curtailment Probability Curve



2019 Adequacy Assessment (Peak Curtailment Probability Curve)



Other Adequacy Metrics

Metric	Description
LOLP (%)	Loss of load probability = number of games with a problem divided by the total number of games
EUSRSP (%)	Use of standby resource probability = Number of games that dispatch standby resources at least once divided by total games
CVaR - Energy (MW-hours)	Conditional value at risk, energy = average annual curtailment for 5% worst games
CVaR - Peak (MW)	Conditional value at risk, peak = average single-hour curtailment for worst 5% of games
EUE (MW-hours)	Expected unserved energy = total curtailment divided by the total number of games
LOLH (Hours)	Loss of load hours = total number of hours of curtailment divided by total number of games
PGC (%)	Percent of games with curtailment = Same as EUSRSP

Adequacy Summary

Metric	2017	2019	Units
LOLP	6.6	5.9	Percent
EUSRSP	9.7	8.3	Percent
CVaR - Energy	99,000	59,200	MW-hours
CVaR - Peak	4,000	3,337	MW
EUE	5,000	3,000	MW-hours
LOLH	2.7	1.7	Hours/year
PGC	9.7	8.3	Percent